

MALONE CAMPBELL ROAD FACILITY, TEXAS CITY, GALVESTON COUNTY, TEXAS

Week ending 10/18/2015

On July 6, 2015 FOSC Zehner initiated an emergency pump down of contaminated storm at the facility which was authorized by the R6 Superfund Division Director. The initiation of emergency actions were necessary to abate the imminent and substantial threat of discharge of several hundred thousand gallons of contaminated storm water located on the Site from several multi-inch rainfalls associated with storm events that had impacted the Site. On-site disposal well WDW-138 began operations on July 6, 2015. The FOSC also authorized the operation of the additional on-site injection well WDW-73. Both injection wells (WDW-138 and WDW-73) are operational, but do have mechanical issues every week. Both wells had no injection on October 13 and 14 due to Pre-Treatment System testing; WDW-73 had not injection on October 16 due to annulus pump issues. Both wells received a total of 150,415 gallons of injectate from October 12 through October 16, for a total injected since emergency response began of 4,613,121 gallons.

Warren Zehner 214-789-1584, David Abshire 214-665-7188